A-X

HIMACHAL PRADESH *
PUBLIC WORKS DEPARTMENT

No. PWI/CB/WA/safety certificate/2021:- -//4- 15

Dated:-

The Principal,
Janak Raj Mahajan,
B.Ed. College GangthTehsil Gangth Distt. Kangra

Subject:-

Request for building safety certificate of college Building for the year 20

With reference to your letter No.3019/2021 dated 07/04/2021 building certificate of Janak Raj Mahajan, B.Ed. College Gangth Tehsil Gangth Distt. kangra is enclosed herewith.

DA/One No.

Executive Engineer, Indora Division HPPWD,

Copy to the Assistant Engineer, Indora Sub-Division HPPWD, Indora information with reference to his office letter No.40 dated 09/04/2021.

Executive Engineer, Indora Division HPPWD, Indora

Josend 2

Principal,
Janak Raj Mahajan
B.Ed. College, Gangath.

CERTIFICATE

The inspection of building of Janak Raj Mahajan, B.Ed. College Gangath Tehsil Gangath Distt. kangra was conducted by the Assistant Engineer, Indora Sub Division, HPPWD., Indora accompanied with Junior Engineer in charge. On the basis of their inspection report, it has been found that no Earthquakes resistant norms have been adopted for the concerned College building. No structure drawing has been approved by the competent Govt. agency produced by the College authority. The structure is a non Engineer structure. Hence the structural safety of this building can't be ensured specially from Earthquake point of view. This Department will not be responsible for any type of loss of life and property etc. if this structure fails under any circumstances.

However, as per visual inspection, the building appears to be safe in appearance and accordingly the College Building Safety Certificate is being issued by this Department from 01/04/202 31/03/2022. This Department could not access the structural safety of building as the same was not constructed under the supervision of this Department.

> Executive Engineer, ndora Division HPPWD,

Principal, Janak Raj Mahajan

B.Ed. College, Gangath.